

CERTIFICATE OF COMPLIANCE

Certificate Number 20170405-E335729
Report Reference E335729-20160427
Issue Date 2017-APRIL-05

Issued to: ICE QUBE INC
141 WILSON AVE
GREENSBURG PA 15601

**This is to certify that
representative samples of**

ROOM AIR CONDITIONERS FOR USE IN HAZARDOUS
LOCATIONS

Air conditioners for use in Class I, Division 2, Groups A, B,
C and D Hazardous Locations.

Models IQ, followed by 4000EV, 5000EV, 6000EV, 8000EV,
10000EV, 12000EV with optional suffixes -H and/or -XP2.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/ISA-12.12.01-2015 & CAN/CSA C22.2 No. 213-16 -
Nonincendive Electrical Equipment for Use in Class I and II,
Division 2 and Class III, Divisions 1 and 2 Hazardous
(Classified) Locations

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

