

CERTIFICATE OF COMPLIANCE

Certificate Number 20171212-SA12062
Report Reference SA12062-20080531
Issue Date 2017-DECEMBER-12

Issued to: ICE QUBE INC
141 WILSON AVE
GREENSBURG PA 15601-2522

**This is to certify that
representative samples of**

AIR CONDITIONERS, SPECIAL PURPOSE
USL, CNL: Electronic control equipment air conditioners,
Models IQ, followed by 5000V16HA, 6000V16HA, 8000T,
8000V16, 8000VB, 8000VHA, 10000V, 12000V, 14000V,
17000V, 20000V may be followed by XP1 or XP2 and/or H.

Rated 120V, 60 Hz or 230V, 60/50 Hz. R407c Refrigerant.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 484 : Standard for Room Air Conditioners,
CSA C22.2 No. 117-1970 : Standard for Room Air
Conditioners and CSA C22.2 No. 236 : Standard for
Heating and Cooling Equipment.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product..



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

