

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160504-E335729  
**Report Reference** E335729-20101214  
**Issue Date** 2016-05-04

**Issued to:** Ice Qube Inc  
141 Wilson Ave,  
Greensburg, PA 15601

**This is to certify that  
representative samples of**

Room Air Conditioners For Use In Hazardous Locations  
See next page for models

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical  
Equipment for Use in Hazardous (Classified) Locations  
ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for  
Use in Class I and II, Division 2 and Class III, Divisions 1  
and 2 Hazardous (Classified) Locations  
CAN/CSA C22.2 No. 30-M1986, Explosion-Proof  
Enclosures for Use in Class I Hazardous Locations  
CAN/CSA C22.2 No. 213-M1987, Non-incendive Electrical  
Equipment for Use in Class I, Division 2 Hazardous  
Locations

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160504-E335729  
**Report Reference** E335729-20101214  
**Issue Date** 2016-05-04

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Air conditioners for use in Class I, Division 2, Groups B, C and D Hazardous Locations.

Models IQ, followed by 2000VXS, 2000TXS, 2000TXS-M1, 2200VB, 2200VS, 2400VXS, 2500TXS, 2500V, 3000T, 3000VS, 3500V, 4000T, 4000V, 4000V16HA, 4000VS, 4500T, 4500V, 5000T, 5000V, 5000V16, 5000V16HA, 5500VS, 6000V, 6000T, 6000V16, 6000V16HA, 7000T, 8000T, 8000VHA, 8000V16, 10000V, 12000V, 14000V, 17000V, 20000V

## Alternate Marking:

Any Products Suitable For Class I, Div. 2 Locations: The following marking (s) may be applied in addition to, or as an alternative to, the class, division and gas group markings required under the following conditions.

- A. Product or products that may be marked Class I, Div. 2, Group D may additionally or alternatively be marked Class I, Zone 2, Group IIA.
- B. Product or products that may be marked Class I, Div. 2, Group C may additionally or alternatively be marked Class I, Zone 2, Group IIB.
- C. Product or products that may be marked Class I, Div. 2, Group B may additionally or alternatively be marked Class I, Zone 2, Group IIB plus hydrogen (OR "+H2"),  
and
- D. Product or products that may be marked Class I, Div. 2, Group B may additionally or alternatively be marked Class I, Zone 2, Group IIC.

Note 1: Equipment that can be marked Group IIB may alternatively be marked Group IIA.

Note 2: Equipment that can be marked Group IIC may alternatively be marked Group IIA or Group IIB.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

